MUSE DOUBLE LIGHT acoustic suspended

091-122163GF

PROJECT		
ТҮРЕ		
NOTES		
QUANTITY		
DATE		

GENERAL

GENERAL
Ceiling
Suspended
felt grey
3670 lm/m
IP20
4400 lm

LED

4000 K	
CRI ≥ 80	
L90 / 50000 h	
initial ≤ 3 MacAdam	

OPTICAL


UGR < 19	
≥65° <1500 cd/m²	

PHYSICAL

Cable 1500 mm	
length 1600 mm	
width 646 mm	
height 700 mm	
9.5 kg	

ELECTRICAL


LLLCINICAL	
DALI-2	
41 W	
107 lm/W	
1 DALI Addr.	
PC1 220-240V	
34 W/m	






Luminaire body made of high-quality, self-supporting polyester fleece with sound absorbing properties, consisting of 50% recycled PET; high-quality visual and tactile surface, felt grey; colour may deviate; constructed of 2 shells to form cavities that improve acoustic performance; large sound absorbing surface; suspended luminaire with 1500mm cable suspension; with integrated tool-less suspension height adjustment; spring clip attachment to the luminaire; freely positionable; incl. transparent feed; optimised for the illumination of 2 office workstations opposite each other; light inset made from extruded profile for improved thermal management; light colour 4000 K; Binning initial \leq 3 MacAdam; CRI \geq 80; min. 90% of luminous flux after 50000 operating hours; energy efficient LEDs with high CRI; high-quality, chromed reflector with faceted design; blind covers in gray; UGR \leq 19; VDU compatible workplace luminaire according to DIN EN 12464-1; luminance above 65° \leq 1500 cd/m²; degree of protection IP20; PC1 220-240V; internal wiring in light halogen free; incl. DALI-2 converter;

Light Distribution





MUSE DOUBLE LIGHT acoustic suspended

091-122163GF

Circuit Breaker Types

Automatic Circuit Breaker Type	Number of Fixtures
B10	7
B13	10
B16	12
B20	14
C10	10
C13	20
C16	24
C20	28

Maintenance Factors

Luminaire Maintenance Factor

Operating	Time [h]	10 000	20 000	30 000	40 000	50 000	
LLMF		0.98	0.95	0.93	0.91	0.9	
LSF		1	1	1	1	1	
MF	LMF × RSMF × LLMF × LSF		RSMF ^a	Room Surface Maintenance Factor			
MF	Maintenance Factor		LLMF	Lamp Lumens Maintenance Factor			

^a According to "CIE 97, Maintenance of indoor electric lighting systems", 2005, ISBN 3-900-734-34-8. The values must be determined by the planner.

Lamp Survival Faktor