

Luminaire

Code GIASS 40
Name GIASS 40

Measurement

Code 0063FT20+0023FT20
Name GIASS 40

Luminaire Flux	1201.20 lm	Luminaire Power	36.00 W	Efficacy	33.37 lm/W	Efficiency	100.00%
Sources Flux	1201.20 lm	Maximum value	566.42 cd/klm	Position	C=0.00 G=2.00	CG	Rotosymmetrical

UGR
S = 0.250

Reflectancies										
Ceiling/Cavity	0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
Walls	0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
Working Plane	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room Dimensions	Lateral View					Viewed Endwise				
x=2H y=2H	17.2	18.4	17.5	18.6	18.9	17.2	18.4	17.5	18.6	18.9
x=2H y=3H	18.6	19.6	18.9	19.9	20.2	18.6	19.6	18.9	19.9	20.2
x=2H y=4H	19.2	20.2	19.6	20.5	20.8	19.2	20.2	19.6	20.5	20.8
x=2H y=6H	19.8	20.7	20.1	21.0	21.3	19.8	20.7	20.1	21.0	21.3
x=2H y=8H	20.0	20.9	20.3	21.2	21.5	20.0	20.9	20.3	21.2	21.5
x=2H y=12H	20.1	21.0	20.5	21.3	21.6	20.1	21.0	20.5	21.3	21.6
x=4H y=2H	17.1	18.1	17.5	18.4	18.7	17.1	18.1	17.5	18.4	18.7
x=4H y=3H	18.6	19.4	19.0	19.8	20.1	18.6	19.4	19.0	19.8	20.1
x=4H y=4H	19.3	20.1	19.7	20.5	20.8	19.3	20.1	19.7	20.5	20.8
x=4H y=6H	20.1	20.7	20.5	21.1	21.5	20.1	20.7	20.5	21.1	21.5
x=4H y=8H	20.4	21.0	20.8	21.4	21.8	20.4	21.0	20.8	21.4	21.8
x=4H y=12H	20.6	21.1	21.0	21.5	22.0	20.6	21.1	21.0	21.5	22.0
x=8H y=4H	19.7	20.3	20.1	20.7	21.1	19.7	20.3	20.1	20.7	21.1
x=8H y=6H	20.4	20.9	20.8	21.3	21.8	20.4	20.9	20.8	21.3	21.8
x=8H y=8H	20.7	21.1	21.2	21.6	22.1	20.7	21.1	21.2	21.6	22.1
x=8H y=12H	21.0	21.4	21.5	21.8	22.3	21.0	21.4	21.5	21.8	22.3
x=12H y=4H	19.7	20.2	20.1	20.6	21.1	19.7	20.2	20.1	20.6	21.1
x=12H y=6H	20.4	20.8	20.8	21.2	21.7	20.4	20.8	20.8	21.2	21.7
x=12H y=8H	20.7	21.1	21.2	21.5	22.0	20.7	21.1	21.2	21.5	22.0

Luminaire

Code GIASS 40
 Name GIASS 40

Measurement

Code 0063FT20+0023FT20
 Name GIASS 40

Luminaire Flux	1201.20 lm	Luminaire Power	36.00 W	Efficacy	33.37 lm/W	Efficiency	100.00%
Sources Flux	1201.20 lm	Maximum value	566.42 cd/klm	Position	C=0.00 G=2.00	CG	Rotosymmetrical

Isolux (Floor)

Luminaire position X=0.00m Y=0.00m Z=2.50m

